

## Classification Report

Number	18-000644-PR01 (NW-A01-02-en-01)
Owner	aluplast GmbH Kunststoffprofile Auf der Breit 2 76227 Karlsruhe Germany
Product	Sliding door scheme A
Designation	System: smart slide
Details	Manufacturer aluplast GmbH, Kunststoffprofile - Karlsruhe; Material Polyvinyl Chloride unplasticized (PVC-U); Type of opening Sliding door (horizontal); Opening direction To the right (seen from inside); Overall dimensions (W x H) 3100 mm x 2400 mm
Special features	

### Result

Operating forces according to EN 13115:2001-07



**Class: 1**

Air permeability according to EN 12207:2016-12



**Class: 4**

Resistance to wind load according to EN 12210:2016-03



**Class: B3**

Watertightness according to EN 12208:1999-11



**Class: 7A**

ift Rosenheim  
07.06.2018



Thomas Stefan, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Component Testing



Franz Gruber  
Operating Testing Officer  
Building Component Testing

### Basis \*)

EN 14351-1:2006+A2:2016-09  
\*) and corresponding national versions  
e.g. DIN EN)

Test report: 18-000644-PR01 PB-  
A01-02-de-01

### Representation



### Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

### Validity

There is no time limit.  
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

### Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: 9BB-9153E